

CONCRETE 300 Airport Dr., NW * Albuquerque, NM 87121 * Phone: 505-836-4404 / Fax: 505-836-5663

Detail # GT-3,000

Not To Scale

June 2009

3000 GREASE TRAP SYSTEM INSTALLATION UTILIZING 2 BOXES

GENERAL NOTES:

- 1. Design specifications conform to latest ASTM C1227 specifications for "Precast Concrete Water and Wastewater Structures"
- 2. Pipe penetration locations as per job requirements. Pipe inlet and outlet locations to have cast-in-place boots. Pipe to be installed by contractor.
- Inlet and outlet requirements such as tee's and/or effluent filters supplies and installed by contractor.
- 4. A minimum of 3" fall required from outlet to inlet between the 2 tanks.
- Casting / Top provided and installed by contractor / customer per job requirements. 2", 3", 4" & 6" grade rings can be supplied by Albuquerque Vault Co. or field adjusted, using approved methods by contractor.
- 6. Excavation hole bottom shall be 2' wide & 2' longer than total outside dimensions.

